



# ENVIRONMENTAL HEALTH & SAFETY

The University of Alabama at Birmingham

## EYE-WASH STATION WEEKLY INSPECTION LOG

### Instructions:

- Must be tested weekly to ensure proper operation in an event of an emergency.
- Equipment is easily accessible, uncluttered, and clearly marked.
- Equipment is flushed for at least 20 seconds or until stream is clear; and is fully operational (e.g., a) water comes out of both eye pieces with the same pressure; b) water is clear; c) equipment not clogged; d) caps are kept on to avoid dust/debris accumulation; e) no water leaks observed etc.,).
- Inspection log sheet is dated with initials weekly.
- Keep weekly eye-wash inspection log sheet for 3 years.
- Notify PI/Lab manager if any issues are found.

<b>Location</b>		<b>Year</b>	
-----------------	--	-------------	--

<b>Month</b>	<b>Week 1 (Date &amp; Initials)</b>	<b>Week 2 (Date &amp; Initials)</b>	<b>Week 3 (Date &amp; Initials)</b>	<b>Week 4 (Date &amp; Initials)</b>	<b>Week 5 (Date &amp; Initials)</b>
<b>January</b>					
<b>February</b>					
<b>March</b>					
<b>April</b>					
<b>May</b>					
<b>June</b>					
<b>July</b>					
<b>August</b>					
<b>September</b>					
<b>October</b>					
<b>November</b>					
<b>December</b>					